




## Window Energy Ratings Certificate 11/B155

**Walker Profiles Ltd**  
**35A Range Road**  
**Motherwell**  
**Lanarkshire ML1 2HR**

The above company's PVC-U windows have been assessed against the requirements of the British Fenestration Ratings Council criteria for the energy rating of windows and achieved the following ratings:

Window system	Rating band	Rating value [kWh·m <sup>-2</sup> ·(year) <sup>-1</sup> ]	$U_{\text{window}}$ (W·m <sup>-2</sup> ·K <sup>-1</sup> )	$g_{\text{window}}$	$L_{\text{factor}}$ (W·m <sup>-2</sup> ·K <sup>-1</sup> )
Profile 22 FC60 PVC-U Casement Window Planilux/Argon/Planitherm Total+ (Swisspacer V)	B	-2	1.4	0.43	0.00
Profile 22 FC60 PVC-U Casement Window Diamant/Argon/Planitherm Total+ (Swisspacer V)	A	2	1.4	0.45	0.00
Profile 22 FC60 PVC-U Tilt/Turn Window Diamant/Argon/Planitherm Total+ (Swisspacer V)	A	0	1.5	0.46	0.01
Profile 22 FC60 PVC-U Tilt/Turn Window Planilux/Argon/Planitherm Total+ (Swisspacer V)	B	-10	1.5	0.42	0.01
Profile 22 FI70 PVC-U Casement Window Planilux/Argon/Planitherm Total+ (Swisspacer V)	B	-1	1.4	0.43	0.00
Profile 22 FI70 PVC-U Casement Window Diamant/Argon/Planitherm Total+ (Swisspacer V)	A	4	1.4	0.45	0.00
Profile 22 FI70 PVC-U Tilt/Turn Window Diamant/Argon /Planitherm Total+ (Swisspacer V)	A	1	1.4	0.46	0.01
Profile 22 FI70 PVC-U Tilt/Turn Window Planilux/Argon/Planitherm Total+ (Swisspacer V)	B	-8	1.4	0.42	0.01
Profile 22 FR70 PVC-U Fully Reversible Window Planilux/Argon/Planitherm Total+ (Swisspacer V)	C	-19	1.5	0.40	0.01



Signed on behalf of the British Board of Agrément:

Date: 18th November 2011

This WER Certificate should not be confused with BBA Agrément Approval, details of which can be found on our website